



HMS-1655 BACnet MS/TP Protocol Implementation Conformance Statement

Date: March 24, 2014

Vendor Name: Triatek Holding LLC

Product Name: HMS-1655 Series Fume Hood Controller with Safety Halo™

Product Model Number: HMS-1655

Firmware Revision: 2.14 or higher

BACnet Protocol Revision: 5

Product Description:

The TRIATEK HMS-1655 Series Fume Hood Controller is an ultra-sensitive instrument used to control and/or monitor the face velocity at the sash opening of laboratory fume hoods. This unit is a precision measuring system capable of measuring and displaying face velocities from zero to 200 ft/min with an accuracy of ± 2 ft/min over the primary operating range of 60 ft/min to 140 ft/min. This particular model fume hood controller is capable of acting as a stand-alone device or as part of a building automation system using the BACnet MS/TP protocol.

BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

List all BACnet Interoperability Building Blocks Supported (Annex K):

DS-RP-B	Read Property
DS-RPM-B	Read Property Multiple
DS-WP-B	Write Property
DM-DDB-B	Dynamic Device Binding
DM-DOB-B	Dynamic Object Binding
DM-DCC-B	Device Communication Control
DS-TS-B	Time Synchronization
DS-UTC-B	UTC Time Synchronization
DM-RD-B	Reinitialize Device

Segmentation Capability:

- Segmented requests supported Yes No
- Segmented responses supported Yes No

Triatek Critical Airstream Controls

Standard Object Types Supported:

Analog Input Object Type

1. Dynamically creatable using BACnet's CreateObject service? Yes No
2. Dynamically deletable using BACnet's DeleteObject service? Yes No

3. List of optional properties supported:

DESCRIPTION

4. List of all properties that are writable where not otherwise required by this standard:

DESCRIPTION
OUT_OF_SERVICE

5. List of proprietary properties:

Property Identifier	Property Datatype	Meaning

6. List of any property value range restrictions:

Property Identifier	Restrictions

Triatek Critical Airstream Controls

Analog Output Object Type

1. Dynamically creatable using BACnet's CreateObject service? Yes No
2. Dynamically deletable using BACnet's DeleteObject service? Yes No

3. List of optional properties supported:

DESCRIPTION

4. List of all properties that are writable where not otherwise required by this standard:

OUT_OF_SERVICE

5. List of proprietary properties:

Property Identifier	Property Datatype	Meaning

6. List of any property value range restrictions:

Property Identifier	Restrictions
PRESENT_VALUE	MINIMUM: 0.0; MAXIMUM: 100.0

Triatek Critical Airstream Controls

Analog Value Object Type

1. Dynamically creatable using BACnet's CreateObject service? Yes No
2. Dynamically deletable using BACnet's DeleteObject service? Yes No

3. List of optional properties supported:

DESCRIPTION PRIORITY_ARRAY RELINQUISH_DEFAULT

4. List of all properties that are writable where not otherwise required by this standard:

OUT_OF_SERVICE

5. List of proprietary properties:

Property Identifier	Property Datatype	Meaning

6. List of any property value range restrictions:

Property Identifier	Restrictions

Triatek Critical Airstream Controls

Binary Input Object Type

1. Dynamically creatable using BACnet's CreateObject service? Yes No
2. Dynamically deletable using BACnet's DeleteObject service? Yes No

3. List of optional properties supported:

DESCRIPTION

4. List of all properties that are writable where not otherwise required by this standard:

5. List of proprietary properties:

Property Identifier	Property Datatype	Meaning

6. List of any property value range restrictions:

Property Identifier	Restrictions

Triatek Critical Airstream Controls

Binary Output Object Type

1. Dynamically creatable using BACnet's CreateObject service? Yes No
2. Dynamically deletable using BACnet's DeleteObject service? Yes No

3. List of optional properties supported:

DESCRIPTION INACTIVE_TEXT ACTIVE_TEXT

4. List of all properties that are writable where not otherwise required by this standard:

OUT_OF_SERVICE

5. List of proprietary properties:

Property Identifier	Property Datatype	Meaning

6. List of any property value range restrictions:

Property Identifier	Restrictions

Triatek Critical Airstream Controls

Binary Value Object Type

1. Dynamically creatable using BACnet's CreateObject service? Yes No
2. Dynamically deletable using BACnet's DeleteObject service? Yes No

3. List of optional properties supported:

DESCRIPTION PRIORITY_ARRAY RELINQUISH_DEFAULT

4. List of all properties that are writable where not otherwise required by this standard:

PRESENT_VALUE OUT_OF_SERVICE

5. List of proprietary properties:

Property Identifier	Property Datatype	Meaning

6. List of any property value range restrictions:

Property Identifier	Restrictions

Triatek Critical Airstream Controls

Device Object Type

1. Dynamically creatable using BACnet's CreateObject service? Yes No
2. Dynamically deletable using BACnet's DeleteObject service? Yes No

3. List of optional properties supported:

DESCRIPTION
 LOCAL_TIME
 LOCAL_DATE
 UTC_OFFSET
 DAYLIGHT_SAVINGS_STATUS
 MAX_MASTER
 MAX_INFO_FRAMES

4. List of all properties that are writable where not otherwise required by this standard:

OBJECT_IDENTIFIER
 OBJECT_NAME
 NUMBER_OF_APDU_RETRIES
 APDU_TIMEOUT
 UTC_OFFSET
 MAX_MASTER
 MAX_INFO_FRAMES

5. List of proprietary properties:

Property Identifier	Property Datatype	Meaning

6. List of any property value range restrictions:

Property Identifier	Restrictions
APDU_TIMEOUT	MINIMUM: 0; MAXIMUM: 3000
NUMBER_OF_APDU_RETRIES	MINIMUM: 0; MAXIMUM: 10
MAX_MASTER	MINIMUM: 0; MAXIMUM: 127
MAX_INFO_FRAMES	MINIMUM: 1; MAXIMUM: 255

Triatek Critical Airstream Controls

Multistate Output Object Type

1. Dynamically creatable using BACnet's CreateObject service? Yes No
2. Dynamically deletable using BACnet's DeleteObject service? Yes No

3. List of optional properties supported:

DESCRIPTION

4. List of all properties that are writable where not otherwise required by this standard:

OUT_OF_SERVICE

5. List of proprietary properties:

Property Identifier	Property Datatype	Meaning

6. List of any property value range restrictions:

Property Identifier	Restrictions
PRESENT_VALUE	MINIMUM: 1; MAXIMUM: 3

Triatek Critical Airstream Controls

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ANSI/ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ANSI/ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s) _____
- MS/TP master (Clause 9), baud rate(s): 9600 bps, 19.2Kbps, 38.4Kbps, 76.8 kbps
- MS/TP slave (Clause 9), baud rate(s): _____
- Point-To-Point, EIA 232 (Clause 10), baud rate(s): _____
- Point-To-Point, modem, (Clause 10), baud rate(s): _____
- LonTalk, (Clause 11), medium: _____
- Other: _____

Device Address Binding:

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) Yes No

Networking Options:

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- | | | |
|---|---|-------------------------------------|
| <input checked="" type="checkbox"/> ANSI X3.4 | <input type="checkbox"/> IBM™/Microsoft™ DBCS | <input type="checkbox"/> ISO 8859-1 |
| <input type="checkbox"/> ISO 10646 (UCS-2) | <input type="checkbox"/> ISO 10646 (UCS-4) | <input type="checkbox"/> JIS C 6226 |

If this product is a communication gateway, describe the types of non-BACnet equipment/networks(s) that the gateway supports:

Not Applicable